



## SUSQUEHANNA RIVER BASIN COMMISSION

4423 North Front Street • Harrisburg, Pennsylvania 17110-1788  
Phone (717) 238-0423 • Fax (717) 238-2436  
Web <http://www.srbc.net>

### Surface Water Withdrawal Application - Renewal Summary

This summary is only a portion of the application materials and is meant to provide general information about the proposed project.

**Source Name:** Martins Creek Surface Water Withdrawal

**SRBC Pending No.:** 2018-105

#### 1. Project Sponsor:

**Company Name:** Sugar Hollow Water Surfaces

**Address:** 21 Sugar Hollow Road

**City:** Tunkhannock

**State:** PA **Zip:** 18657

**Contact Person:** Bill Hampton

**Title:** General Manager

**Telephone:** 5708366129

**Fax:** 570-836-1153

**Mobile:** 570-233-8247

**E-mail:** [bill.hampton@sugarhollowwater.com](mailto:bill.hampton@sugarhollowwater.com)

#### Facility Location:

**State:**

PA

**County:**

Susquehanna

**Municipality:**

Hop Bottom Borough

**Subbasin:**

Middle Susquehanna

**Date operations will begin:**

12/4/2010

**Date project sponsor began operation:**

6/1/2015

#### 4. Project Water Requirements:

| Water Use:       | Past       | Existing   | Projected  |
|------------------|------------|------------|------------|
| Average:         | 0.36 (mgd) | 0.36 (mgd) | 0.36 (mgd) |
| Maximum:         | 0.36 (mgd) | 0.36 (mgd) | 0.36 (mgd) |
| System Capacity: | 0.36 (mgd) | 0.36 (mgd) | 0.36 (mgd) |

#### 5. Requested Use or Withdrawal:

|  |      |
|--|------|
| Estimated Hours of Operation:                | 24   |
| Maximum Instantaneous Withdrawal Rate: (gpm) | 250  |
| Peak 24-Hour Day: (mgd)                      | 0.36 |
| Maximum 30 Day Average: (mgd)                | 0.36 |

#### 12. Environmental Resource Information:

Name of stream / river reach:

Martins Creek

Water Use Classification:

CWF

**Waterbody Status Information:**

Pennsylvania 303(d) or Priority Waterbody List Status:

Attaining

**Wild or Scenic:**

Is the stream or river reach designated wild and / or scenic?

No

**13. Proposed Surface Water Withdrawal Source:**

Source from which withdrawal is being requested: Stream

Q7-10 Low Flow at point of taking (cfs): 2

Drainage Area (square miles): 44.4

Is this a public water supply? No

**What is the percentage of the Requested Quantity of Withdrawal compared to the Q7-10 Low Flow?**

Maximum 30 Day Average: 18

Maximum Day: 18

### **Existing Facility Information**

The existing water withdrawal and staging area are on property owned by Kurt Kulick and the withdrawal is operated by Sugar Hollow Water Services, LLC. The site is located in Hop Bottom Borough, Susquehanna County, PA. The withdrawal site includes a surface water withdrawal from Martins Creek and staging area. Martins Creek is designated as a CWF-MF under PA Code 25 Chapter 93. The existing withdrawal includes an intake strainer/pump, a flow meter, and three manifolded frac tanks, allowing three trucks to fill at one time.

A surface water withdrawal of up to 360,000 gallons per day with a maximum instantaneous withdrawal rate of up to 250 gallons per minute from Martins Creek (CWF-MF) is approved under Docket No. 20150304-1.

No modifications are proposed at this time. The purpose of this application is a renewal of the surface water withdrawal docket.